

Nashua Fire Rescue

Fire Marshal's Office

177 Lake Street, Nashua NH 03060-4402 NashuaNH.gov Adam Pouliot Fire Marshal (603) 589-3460 Fax (603) 589-3474

Nashua Pre-Construction Information NFPA 1 and NFPA 241

Access into the construction site will require a Knox box or lock (Forms can be downloaded from the NFM website).
Every building shall be accessible by fire department apparatus by means of roadways having an all-weather driving surface of not less than 20 feet of unobstructed width, having the ability to withstand the live loads of fire apparatus (construction materials, equipment, dumpsters, etc.).
Any use of generators shall have a 10 foot clearance from all structures.
Any structures with an address shall be posted in front of the entrance or on the building with contrasting colors.
Yard hydrants (if applicable) NFPA 241, 8.7.2.1 A water supply for fire protection, either temporary, or permanent shall be made available as soon as combustible material accumulates.
Fire extinguishers are to be placed in plain sight and travel distance does not exceed 50 feet NFPA 241.
Hot Works – Permit required (Forms can be downloaded from the NFM website).
Emergency Contact Information form shall be filled out prior to any construction. (Forms can be downloaded from the NFM website).
Standpipe systems (if applicable) NFPA 241, 7.6 In all new buildings in which standpipes are required or where standpipes exist in buildings being altered or demolished, such standpipes shall be maintained in conformity with the progress of building construction in such a manner that they are always ready for use (Standpipe systems should be extended by floor as construction takes place).
Sprinkler Protection – NFPA 241, 8.7.3.1 If automatic sprinkler protection is to be provided, the installation shall be placed in service as soon as practicable.
Master Box Requirements (if applicable) can be obtained online.
All permits shall be posted on site for review.
City of Nashua Ordinance O-22-023 - Re-inspection Fee \$150.00 (Each Inspection) After 1 st failed final inspection of permit.