



# Nashua Fire Rescue

## Fire Marshal's Office

177 Lake Street, Nashua NH 03060-4402  
[NashuaNH.gov](http://NashuaNH.gov)

Adam Pouliot  
Fire Marshal  
(603) 589-3460  
Fax (603) 589-3474

## Food Truck/Trailer Inspection

- Current DMV registration and state inspection sticker
- Wheel chocks shall be used to prevent mobile and temporary cooking units from moving. (NFPA 1 2018, 50.7.1.3)

### Fuel type for cooking

- LPG
- Electric
- LPG fuel supply to the cooking equipment shall be NFPA 58 compliant and is the sole responsibility of the applicant to have said system installed and maintained by a licensed gas fitter.
- All mobile and temporary cooking operations equipped with a propane appliance and electrical system shall be equipped with a propane detector listed and marked on the device as being suitable for use in vehicles under the requirements of UL 1484, and installed to the terms of its listing. The LP-Gas leak detection system shall be tested monthly.

### Cooking equipment

- Layout under the hood
- Baffle between deep fat fryers and open flames (minimum 8" in height measured from the higher of the two)
- Cover for the deep fat fryer

### Hood System

- Grease laden vapor requires type 1 hood and duct work (Valid hood inspection sticker)
- UL 300 system for the hood suppression (6 Month inspection)
- K type fire extinguisher (Annual inspection)
- 2A:10BC fire extinguisher minimum (Annual inspection)

Applicant: \_\_\_\_\_  
Business Name

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Inspector: \_\_\_\_\_ Date: \_\_\_\_\_