



Nashua Fire Rescue
Fire Marshal's Office
177 Lake Street, Nashua NH 03060-4402
NashuaNH.gov

Adam Pouliot
Fire Marshal
(603) 589-3460
Fax (603) 589-3474

Annual Fire Hydrant Inspection
Per NFPA 25

Inspections must be completed and the forms submitted to the Nashua Fire Marshal's Office no later than November 1st of each year.

Property Name: _____ Tel: _____
Address: _____
Email: _____
Date of Inspection: _____ No. of Hydrants: _____
Date of Last Flow Test _____

CONDITION

- Accessibility
- Barrel contains water or ice (Presence of water or ice may indicate faulty drain, a leaky hydrant valve, or groundwater table).
- Improper drainage from barrel.
- Leaks in outlets or at top of hydrant.
- Cracks in hydrant barrel.
- Tightness of outlets.
- Worn nozzle threads.
- Worn hydrant operating unit.
- Lubricate threads.
- Flow hydrant until all debris is cleaned out, at least one minute. **(annual requirement)**
- Underground and exposed piping shall be flow tested to determine the internal condition of the piping **every 5 years**. Results of the flow tests need to be sent to the Nashua Fire Marshal's Office.

CORRECTIVE ACTION

- Make accessible. **A 3 foot clear space shall be maintained around the circumference of the fire hydrant at all times.**
- Repair and drain; for high groundwater, it may be necessary to plug the drain and pump out the barrel after each use.
- Repair drain.
- Repair or replace gaskets, packing or parts as necessary.
- Repair or replace.
- Lubricate if necessary; tighten if necessary.
- Repair or replace if worn.
- Repair or replace.

I CERTIFY THAT ALL HYDRANTS ON THIS PROPERTY HAVE BEEN INSPECTED IN THE ABOVE MANNER AND ALL DEFICIENCIES HAVE BEEN CORRECTED.

SIGNATURE/TITLE